



Office of  
**EXECUTIVE ENGINEER, NERCHOWK DIVISION**  
Himachal Pradesh Public Works Department Nerchowk  
Ph. 01905-243262, E-mail [eepwd-nerchowk-hp@gov.in](mailto:eepwd-nerchowk-hp@gov.in)

No.PW-NCD-CB-WA/Building Safety/2025-26-4450-51 Dated:- 8/9/25

To


✓ The Principal,  
Abhilashi College of Education,  
Nerchowk, Tehsil Balh, Distt. Mandi (H.P.)

**Subject: - Regarding Building Safety Certificate.**


**Reference: - Your office letter No. ACE/B.ED/5024 dated 04-09-2025.**

With reference to your office letter quoted under reference, it is intimated that the building namely Abhilashi College of Education Nerchowk, Tehsil Balh, Distt. Mandi (H.P.) inspected by the Assistant Engineer, Chakkar Sub-Division, HPPWD Nerchowk and seen that this college is four storey buildings. This department neither supervised above buildings during construction at any stage nor foundation depth, quality of material used & cement concrete ratio used known/checked. Moreover, no detailed structural analysis and drawings in seismic and non-seismic conditions are available to check the safety of buildings. However, as per submitted architectural drawings and on visual inspection, the buildings seems to be safe in normal condition to run college for the academic year 2025-26 with the following terms and conditions:-

- 1) This certificate stands to be cancelled if any additional/alteration to school building as per the architectural drawing submitted as above are made or any other load is increased on building.
- 2) This department holds no responsibility regarding safety of building during natural calamity i.e. earthquake, cloud burst, floods, unequal settlement etc.  
Also, the buildings are disabled friendly.

  
**Executive Engineer,  
HPPWD Division Nerchowk,  
Distt. Mandi (H.P.)**

Copy to the Assistant Engineer, Chakkar Sub-Division HPPWD Nerchowk w.r.t his office letter No. 1298-99 dated 08-09-2025 for information.

  
**Executive Engineer,  
HPPWD Division Nerchowk,  
Distt. Mandi (H.P.)**